

From: Whitehead, Eugene K. <EKWhitehead@co.pg.md.us>
Sent: Thursday, September 12, 2024 10:22 AM
To: Gonzalez, Jose <jgonzalez@dewberry.com>; Prince George's Soil Conservation District <pgscd@co.pg.md.us>
Cc: Freiland, Sharon <sfreiland@Dewberry.com>; Cadwallader, Jonas <icadwallader@Dewberry.com>
Subject: RE: FSC#140-23_Online submittal_2nd submission

[CAUTION] External Email. DO NOT click links or open attachments unless expected. Please use the "Phish Alert" button to report all suspicious emails.

Good morning Jose,
I did review the submittal and I am seeking clarification on our end. We appear to be close to approval stage based on your responses. You should hear back from me on that by tomorrow.

Thanks,
Gene Whitehead

Urban Development & Conservation Engineer

To ensure timely processing please direct ALL ELECTRONIC PLAN SUBMISSIONS to pgscd@co.pg.md.us. If resubmitting, direct a copy to the assigned reviewer as well. Note 30 MB attachments size limit.



ekwhitehead@co.pg.md.us

www.pgscd.org

5301 Marlboro Race Track Rd. Suite 100; Upper Marlboro, MD 20772

9400 Peppercorn Place, Suite 219; Largo, MD 20774

Main: 301-574-5162 ext 3 Largo: 301-883-3265

Direct: 202-505-3373

From: Miller, Julie O. <JOMiller@co.pg.md.us>
Sent: Friday, June 14, 2024 12:29 PM
To: Freiland, Sharon <sfreiland@Dewberry.com>
Cc: Cadwallader, Jonas <jcadwallader@Dewberry.com>
Subject: RE: Beaverdam Creek Watershed, FSC# 141-23

[CAUTION] External Email. DO NOT click links or open attachments unless expected. Please use the "Phish Alert" button to report all suspicious emails.

Good afternoon, Sharon,

Please address the following outstanding comments:

1. Provide DOE Concept and final SWM approval.
2. Provide approved NRI.
3. Provide floodplain approval.
4. Clarify facility elevations in the small pond exemption request letters. Be sure to clarify the elevation below the 3" mulch layer and the 10yr WSEL.

Please let me know if you have any questions.

Thank you,

Julie